

ORDINANCE NO. 94-38

AN ORDINANCE APPROVING THE BIDS FOR ELECTRICAL SUPPLIES

WHEREAS, the Village sought and obtained five bids for twenty (20)-25. KVA Transformers, ten (10) - 50 KVA Transformers, twenty-five thousand (25,000) feet of 1/0 wire and fifteen thousand (15,000) feet of Mammouth 4/0 wire and ten thousand (10,000) feet of 4/0 Hendrix Wire on June 10th 1994, and


WHEREAS, the Public Works Committee met on June 21, 1994 to review the bids and is recommending the material be purchased in larger quantities at bid price as follows:

<u>ITEM</u>	<u>COMPANY</u>	<u>PRICE</u>	<u>TOTAL COST</u>
25 KVA Transformers	Graybar Electric	843.95 each	\$25,318.50
50 KVA Transformers	Graybar Electric	1069.95 each	\$16,049.25
1/0 Wire	Brownstown Electric	1.194 per ft	\$41,790.00
4/0 Wire Mammouth	Brownstown Electric	1.15 per ft	\$28,750.00
4/0 Wire Hendrix	Brownstown Electric	3.164 per ft	\$63,280.00


NOW, THEREFORE BE IT ORDAINED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF CHATHAM, ILLINOIS, AS FOLLOWS:

SECTION 1: The findings in the preamble hereto are hereby adopted.

SECTION 2: This Ordinance is effective upon its passage and approval.


 Linda L. Koester, President
 Village of Chatham
 DAVID JASWIAK - Mayor Pro Tem

ATTEST:


 Penny Mooney, Village Clerk

AYES: 6
 NAYS: 0
 ABSENT: _____

PASSED: 6-28-94
 APPROVED: 6-28-94

VILLAGE OF CHATHAM

VILLAGE PRESIDENT
Linda Koester

VILLAGE CLERK
Penny Moomey

VILLAGE ADMINISTRATOR
Del McCord

Phone (217) 483-2451 • Fax (217) 483-3574
116 East Mulberry • Chatham, Illinois 62629

TRUSTEES
David Hilt
Dave Joswiak
Bob Krueger
Tom McGuire
Rose Miller
Mike Williamsen

June 02, 1994

REQUEST FOR BID

The Village of Chatham, Illinois, will be accepting bids for the material listed below until Friday, June 10, 1994 at 2:00 P.M.

Please review the enclosed transformer loss evaluation information and include all necessary information to make this calculation on your new transformer.

MATERIAL:

- 1- 20 - NEW 25 KVA PADMOUNT TRANSFORMER
7200/12,470 GRD. Y
120/240 SECONDARY
2 HIGH VOLTAGE BUSHINGS WITH BUSHING WELLS AND BUSHING WELL INSERTS
SECONDARY SIDE 5/8" STUDS WITH 8 HOLE SECONDARY
BARS INSULATED; NO TAPS
- 2- 10 - NEW 50 KVA PADMOUNT TRANSFORMER (SAME SPECS. AS ABOVE)
- 3- 25,000 FT. - HENDRIX 1/0 TR X LP - 220
1/0, 15 KV ALUMINUM URD CABLE
.220 MIL. TR X LP
EZ STRIP, 2,500 FT. SPOOLS
- 4- 15,000 FT. MONMOUTH - 4/0 - 4/0 - 4/0
ALUMINUM (1,000 FT. SPOOLS)
- 5- 10,000 FT. - HENDRIX 4/0 TR X LP - 220
4/0 - 15 KV COPPER URD CABLE
.220 MIL. TR X LP
EZ STRIP, 2,500 FT. SPOOLS

Please specify delivery time for all material. For more information on bid material, please contact Shane Hill at 217-483-2451.

All bids should be signed, mail or hand delivered by the above date and time in a sealed envelop marked "ELECTRIC MATERIAL BID" to:

VILLAGE OF CHATHAM
116 E. MULBERRY ST.
CHATHAM, ILLINOIS 62629
ATTN.: MEREDITH BRANHAM

VILLAGE TREASURER
Daniel Bedell

PUBLIC WORKS DIRECTOR
Meredith Branham

OFFICE MANAGER
JRH Butler

CHIEF OF POLICE
Roy Barnett

Incorporated March 24, 1874