

VILLAGE OF CHATHAM, ILLINOIS

---

ORDINANCE NO. 99 - 65

AN ORDINANCE APPROVING A BID FOR ELECTRICAL TRANSFORMER

---

ADOPTED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF  
CHATHAM, ILLINOIS THIS 21<sup>ST</sup> DAY OF DECEMBER, 1999

---

Published in pamphlet form by the authority of the President and  
Board of Trustees of the Village of Chatham, Sangamon County,  
Illinois, this 21<sup>ST</sup> day of December, 1999.

ORDINANCE NO. 99-65

AN ORDINANCE APPROVING A BID FOR ELECTRIC TRANSFORMER

WHEREAS, the Village of Chatham sought and obtained bids for a 1500 kVA transformer with 480Y/277 V. secondary voltage, with load break bushing inserts; and

WHEREAS, the attached bid was opened and the lowest responsible bidder identified; and


WHEREAS, on the Public Works Committee met to review the bids and is recommending the from Pauwels Transformer Inc. for \$12,787.

NOW, THEREFORE, BE IT ORDAINED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF CHATHAM, ILLINOIS, AS FOLLOWS:

SECTION 1: That the bid from Pauwels Transformer Inc. is hereby approved.

SECTION 2: This Ordinance is effective upon its passage and approval.

PASSED THIS 21<sup>st</sup> DAY OF DECEMBER, 1999

  
Linda L. Koester, President  
Village of Chatham

ATTEST:

  
Robert A. Krueger, Village Clerk

AYES: 5

NAYS: 0

ABSENT: Boyle

PASSED: 12/21/99

APPROVED: 12/21/99

*mailed 11/17/99*



# QUICK-SHIP PROGRAM

Customer: Fletcher-Reinhardt

From: Mike Hitchcock

End-user: City of Chatham, Inc.

Tel: 314/239-6783 ext. 337

Fax: 314/239-1926

FROM

By: Tim Moriarty

Date: 11-17-99

Fax: 314-506-0705

Unit price (not incl. adders): \$ 12437.00 Ship weeks A.R.O.: 1-2

Yes  No Adders for optional features (see attached page)

- ◊ All stocked units are subject to prior sales without notice.
- ◊ Allow two (2) weeks for units to ship.
- ◊ Stocked units can not be held without a purchase order.

*ADD \$350 FOR LOAD BREAK BUSHING INSERTS*

# Units: 1 (One Transformer Type/Design per quote sheet)

kVA -size:  75  150  300  500  750  1000  1500  2000

Sec. Voltage:  208Y/120 V.  480Y/277 V.

Loss levels: No-Load (W): \_\_\_\_\_ Load (W): \_\_\_\_\_ %IZ: \_\_\_\_\_

Prim. Voltage:  
 12,470 GrdY/7,200 V

Prim. Taps  
 ± 2@ 2.5%

Temp. Rise:  
 65° C

Liquid type used:  
 Mineral oil

Feed:  
 Loop

Bushing arrangements:  
 ANSI Specific

L.V. terminations  
 Spades per ANSI  
 Spade support on 10 Hole spades only

Dead Front H.V. Terminations:  
 Wells

| # of HOLES | 75 | 150 | 300 | 500 | 750 | 1000 | 1500 | 2000 |
|------------|----|-----|-----|-----|-----|------|------|------|
| 208Y/120 V | 4  | 4   | 4   | 6   | 10  | -    | -    | -    |
| 480Y/277 V | 4  | 4   | 4   | 4   | 6   | 6    | 6    | 10   |

- Accessories:
- Drain valve w/sampler (750 kVA and above)
  - Steel barrier
  - 19" deep air-compartment
  - 24" deep air-compartment (300 kVA and above)
  - Press. relief device (Qual. 202-037-01)

- Dripshield
- Pentahead bolts

- Provisions for:
- Liq. level gauge
  - Liq. temp. gauge

Fusing:  
 Bayonet

Paint:  
 Munsell green (7.0G/3.29/1.5)

Rev.: 9/1/99

FLETCHER-REINHARDT CO  
 3105 CORPORATE EXCHANGE CT  
 BRIDGETON MO 63044  
 314-506-0700 FAX 314-506-0705

*11/17/99*

*Timothy J. Moriarty*

ORDINANCE CERTIFICATE

STATE OF ILLINOIS     )  
                                  )  SS.  
COUNTY OF SANGAMON   )

I, the undersigned, do hereby certify that I am the duly qualified and acting Village Clerk of the Village of Chatham, Sangamon County, Illinois.

I do further certify that the Ordinance attached hereto is a full, true, and exact copy of Ordinance No. 99-64, adopted by the President and Board of Trustees of said Village on the 21<sup>st</sup> day of December, 1999, said Ordinance being entitled:

AN ORDINANCE APPROVING A BID FOR ELECTRICAL TRANSFORMER

I do further certify that prior to the making of this certificate, the said Ordinance was spread at length upon the permanent records of said Village, where it now appears and remains.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed the official seal of said Village this 21<sup>st</sup> day of December, 1999.

Robert A. Krueger, Village Clerk