



# ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276 • (217) 782-3397

PAT QUINN, GOVERNOR

JOHN J. KIM, DIRECTOR

217/782-1724

February 19, 2013

Chairman, South Sangamon Water Commission  
Post Office Box 83  
New Berlin, Illinois 62670

Re: SOUTH SANGAMON WATER COMMISSION (Sangamon County - - 1670080)  
Contract "C" Water Treatment Plant - High Service Pump Modifications/Permit No.  
0185-FY2013  
'As-Built' Operating Permit

Ladies and Gentlemen:

The Illinois Environmental Protection Agency (Agency) is in receipt of the plans and specifications, prepared by Donahue & Associates, Inc., for the installation of two (2) additional high service pumps (each with a capacity of 600 gpm @ 127 ft TDH) and modifications to the three (3) permitted high service pumps (each with a capacity of 1,150 gpm @ 360 ft TDH). This documentation has been received by this office and has been reviewed for compliance to minimum design and construction requirements for Illinois public water supplies.

Based on the "as-built" information submitted, it appears that the improvements made to your public water supply conform to minimum requirements for public water supply construction. Section 15 of the environmental Protection Act states "Owners of public water supplies, their authorized representative, or legal custodians, shall submit plans and specifications to the Agency and obtain written approval before construction of any proposed public water supply installations, changes, or additions is started." Therefore, in the future the plan data for any changes or additions to the supply must be submitted and approved prior to the start of construction.

This letter may be considered an operating permit for the improvements to the public water supply described above. If you have any questions or require further assistance please contact Christopher Kohrman of my staff at [Christopher.Kohrman@illinois.gov](mailto:Christopher.Kohrman@illinois.gov) or at 217/782-1724.

Sincerely,

David C. Cook, P.E.  
Acting Manager, Permit Section  
Division of Public Water Supplies

DCC:CLK

CC: Donahue & Associates, Inc.